

**April 2005**

## **Pecora Deck 800 Polyurethane Deck Coating UL790 Standard Test Methods for Fire Tests of Roof Coverings**

Pecora Deck 802 Base, 804 Intermediate and 806 Top Coat, when tested according to UL 790, “Standard Test Method for Fire Tests of Roof Coverings”, meets Class A criteria.

### **FLUID APPLIED COATING SYSTEMS**

**Class A Classification**

**Deck: NC    Incline: 3**

This will include all Pecora Deck Coating 800 Systems that are comprised of the 802 Base, 804 Intermediate and 806 Top coats and/or any combination.

Note: Independent laboratory test results are available upon request.

