

Test Verification of Conformity

Verification Number: 103291284GRR-001bRV

On the basis of the tests undertaken, the sample of the below product has been found to comply with the requirements of the referenced specification/standard at the time the tests were carried out. This verification is part of the full test report and should be read in conjunction with it.

Applicant Name & Address:	Steven Lawrey Pecora Corporation 165 Wambold Road Harleyville, PA 19438 USA
Product Description:	DynaTrol™ I-XL General Purpose Polyurethane Sealant
Ratings & Principle Characteristics:	CDPH 01350: This product conforms to formaldehyde and individual VOC requirements specified in California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 Table 4-1 for the School Classroom, Private Office and Single-family Residence scenarios as defined in Tables 4-2, 4-4 and B-1 respectively. LEED v4: Indoor air concentrations for TVOCs are < 0.5 mg/m ³ for Private Office and School Classroom scenarios and between 0.5 and 5.0 mg/m ³ for Single-family Residences.
Models/Type References:	DynaTrol™ I-XL General Purpose Polyurethane Sealant
Brand Name:	Pecora
Specification/Standard:	California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017
Verification Issuing Office Name & Address:	Intertek 4700 Broadmoor SE Kentwood, MI 49412
Test Report Number:	103291284GRR-001bR


Signature

Name: Jesse Ondersma, Ph.D.
Position: Department Manager
Date: 26-June-2018

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.